## BUILDING SAFETY CERTIFICATE

Dated: 24/0	6   2023
Dated:	24/0

Certified that the existing building Maharishi Vidya Mandix (name of the building or premises) at B.E.L. Road, Havisingh pur, Kotdwara
building or premises) at B.E.L. Road, Harisinghpur, Kotdwara
(address) comprised of basement(s) and
Groundflow, First floor & Second floor (upper floors) owned/occupied by Maharishi Vidya Mandir Public School, B.E.L Road, Kotdwara,
Manarshy Vidya Mandir Kublic School, B.E.L Road, Kota Loara,
Building safety requirements in accordance with National Building code Rules, and verified by
the officers concerned of P. M.D(Name of Department/ Govt.)
on23
The Bincipal Ravindar Singh Gusain, (name and addresses of the
Manager/Secretary or his representative) and that the building/premises is fit for occupancy
upto classesXII. (X/ XII) with effect from 24.06.2023 for a period of
years in accordance with rule and subject to compliance of the specific
conditions as appended.
1. Ramp/Railing is provided for physically handicapped students.
2. Stair Case width 1s 1: 50 mts, Rise of steps is 0.15 mts.
2. Stair Case width is 1.50 mts, Rise of steps is 0.15 mts. 3. Ceiling Keight from grand floor measured and it is 3.00 nntss. 4.
4.
Issued on .2A106  2023 at

Signature with Seal:

Name : निर्माण खण्ड लो निर्मा

Designation : A.E. GUSSI

Name & Address of Department/ Office: Ashien Singh

(Assistant Engineer & above officer of concerned Govt. Department only) Kordwara

Note: This certificate should be signed / issued by Assistant Engineer & above officer of concerned Govt. Department only

<sup>\*</sup> Strike out whichever is not applicable.

<sup>\*</sup> The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.